



**ISOMETRIC VIEW**  
SHOWING ROOF, WINDOW, HIP AND CHIMNEY PROTECTION

**END ELEVATION**  
SHOWING CHIMNEY AND ROOF PROTECTION

General Notes

**NOTES:**

- ONE LAYER OF THATCH-SAFE® TO BE LAID, ALUMINIUM SIDE UPPERMOST, OVER THE RAFTERS. TO BE SECURED BY BATTENS 50mm x 20 mm AT 250mm INTERVALS. THE BATTENS TO BE FIXED BY 3 INCH GALVANISED NAILS TO THE RAFTERS. ALL JOINS TO BE OVERLAPPED BY 100mm AND WHERE NECESSARY TO BE SECURED BY AN EXTRA BATTEN.
- TWO LAYERS OF THATCH-SAFE® TO BE LAID AROUND THE CHIMNEY, THE FIRST LAYER TO HAVE THE FOIL FACING THE CHIMNEY, THE SECOND LAYER TO HAVE THE FOIL FACING THE THATCH. THE THATCH-SAFE® TO BE SECURED BY BATTENS 50mm x 20 mm AT THE TOP AND BOTTOM. THE MAXIMUM PITCH OF THE BATTENS TO BE NO GREATER THAN 250mm INTERVALS. ALL JOINS TO BE OVERLAPPED BY 100mm AND WHERE NECESSARY ARE SECURED BY AN EXTRA BATTEN.

No.	Revision/Issue	Date

Firm Name and Address  
SMF CROUCH AND CO LTD  
2 TROTTS LANE, MARCHWOOD,  
SOUTHAMPTON,  
HAMPSHIRE  
SO40 4UE  
Tel: 023 8087 3628

Project Name  
THATCH-SAFE® FIRE RETARDANT  
APPLICATION AND SPECIFICATION.

Project	TAC 1548	Drawing	1
Date	07/12/07	Scale	1:15
Dimensions in	mm		